



TYPE APPROVAL CERTIFICATE

Certificate No:
TAE000026Z
Revision No:
2

This is to certify:

That the **Switchboard wire**

with type designation(s)
TEXILine HF90 0,6/1 kV

Issued to

amo specialkabel AB
ALSTERMO, Sweden

is found to comply with

DNV rules for classification – Ships, offshore units, and high speed and light craft

Application :

General power and lighting

Products approved by this certificate are accepted for installation on all vessels classed by DNV.

Issued at **Høvik** on **2023-07-03**

This Certificate is valid until **2028-05-28**.

DNV local unit: **Malmö**

Approval Engineer: **Ivar Bull**

for **DNV**

Frederik Tore Elter
Head of Section

This Certificate is subject to terms and conditions overleaf. Any significant change in design or construction may render this Certificate invalid. The validity date relates to the Type Approval Certificate and not to the approval of equipment/systems installed.

LEGAL DISCLAIMER: Unless otherwise stated in the applicable contract with the holder of this document, or following from mandatory law, the liability of DNV AS, its parent companies and their subsidiaries as well as their officers, directors and employees ("DNV") arising from or in connection with the services rendered for the purpose of the issuance of this document or reliance thereon, whether in contract or in tort (including negligence), shall be limited to direct losses and under any circumstance be limited to 300,000 USD.



Product description

TEXILINE HF90 0,6/1 kV

Construction: Single wire
 Conductors: Plain or tinned stranded copper. Class 5
 Core insulation: HF90

No of cores:	Cross sectional area [mm ²]
1	1 - 240

Application/Limitation

Wires with flexible conductors (IEC 228 class 5) are to be terminated using approved compression terminals intended and designed for these conductors.

Type Approval documentation

Tests carried out

Standard	Release	General description	Limitation
DNV CP-0399	2021-08	Electric cables.	
IEC 60092-350	2020-01	Electrical installations in ships - Part 350: General construction and test methods of power, control and instrumentation cables for shipboard and offshore applications	
IEC 60092-360	2021-01	Electrical installations in ships - Part 360: Insulating and sheathing materials for shipboard and offshore units, power, control, instrumentation and telecommunication cables	
IEC 60092-353	2016-09	Electrical installations in ships - Part 353: Power cables for rated voltages 1 kV and 3 kV	
IEC 60332-1-2	2006-07	Tests on electric cables under fire conditions. Test for vertical flame propagation for a single insulated wire or cable.	
IEC 60754-1	2019-11	Test on gases evolved during combustion of materials from cables - Part 1: Determination of the halogen acid gas content	Low Halogen: <0,5% Halogen

Marking of product

AMOKABEL TEXILine HF90 - size - IEC 60092-353 - 1 kV – DNV - YYWW

Periodical assessment

The scope of the periodical assessment is to verify that the conditions stipulated for the Type approval are complied with and that no alterations are made to the product design or choice of materials.

The main elements of the assessment are:

- Inspection on factory samples, selected at random from the production line (where practicable)
- Results from Routine tests (RT) and selected type tests (ref. to applicable class programs) checked (if not available these tests shall be carried out)
- Review of type approval documentation
- Review of possible change in design, materials and performance
- Ensuring traceability between manufacturer's product type marking and Type Approval Certificate.

Periodical assessment is to be performed after 2 years and after 3.5 years. A renewal assessment will be performed at renewal of the certificate.

END OF CERTIFICATE